



Marine &amp; Offshore

Certificate number: 44225/B0 MED

File number: AP 4671

Item number: MED/3.51f

This certificate is not valid when presented without the full attached schedule  
composed of 7 sections  
www.veristar.com

Notified Body 2690 - MARINE EQUIPMENT DIRECTIVE 2014/90/EU

## EC TYPE EXAMINATION CERTIFICATE

as per Module B of Directive 2014/90/EU of the European Parliament and of the Council of 23 July 2014 as transposed in the French Regulations and Commission Implementing Regulation (EU) 2021/1158 of 22 June 2021

This certificate is issued to:

**DETECTOMAT SYSTEM**

AHRENSBURG - GERMANY

for the type of product

**FIXED FIRE DETECTION AND FIRE ALARM SYSTEMS COMPONENTS [...] -  
MANUAL CALL POINTS**

DMOCLIEx and DMCL05

**Requirements:**

IMO Res. MSC.36(63) -(1994 HSC Code)- as amended, 7

IMO Res. MSC.97(73) -(2000 HSC Code)- as amended, 7

IMO Res. MSC.98(73) -(FSS Code)- as amended, 9

IMO Res. MSC.391(95) -(IGF Code)- as amended, 11

IMO MSC.1/Circ.1242

EN 54-11:2001 incl. /A1:2005

As applic., electrical and electronic installation in ships:

IEC 60092-504:2016

IEC 60533:2015

This certificate is issued on behalf of the French Maritime Authorities to attest that Bureau Veritas Marine & Offshore did undertake the relevant type-examination procedures for the product identified above which was found to comply with the relevant requirements of the Directive 2014/90/EU of the European Parliament and of the Council of 23 July 2014 as transposed in the French Regulations.

**This certificate will expire on: 11 Oct 2026****For Bureau Veritas Marine & Offshore Notified Body 2690,**

At BV SAINT-NAZAIRE, on 11 Oct 2021,

Francois LOPINOT



This certificate does not allow to issue the Declaration of Conformity and to affix the mark of conformity (wheelmark ) to the products corresponding to this type. To this end, the production-control phase module (D, E or F) of Annex II of the Directive is to be complied with and controlled by a written inspection agreement with a notified body.

This certificate remains valid until the date stated above, unless cancelled or revoked, provided the conditions indicated in the subsequent page(s) are complied with and the product remains satisfactory in service. This certificate will not be valid if the applicant makes any changes or modifications to the approved product, which have not been notified to, and agreed in writing with Bureau Veritas Marine & Offshore. Should the specified regulations or standards be amended during the validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on board vessels to which the amended regulations or standards apply. Bureau Veritas Marine & Offshore is designated by the French Maritime Authority as a "notified body" under the terms of the French Regulations Division 140 Chapter 140-2. This certificate is issued within the scope of the General Conditions of Bureau Veritas Marine & Offshore available on the internet site www.veristar.com. Any Person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas Marine & Offshore for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by personnel of the Society or of its Agents in establishment or issuance of this document, and in connection with any activities for which it may provide.

## THE SCHEDULE OF APPROVAL

### **1. PRODUCT DESCRIPTION:**

- Product model or type designation :  
**DMOCLIE<sub>x</sub>** and **DMCL05**
- Product description:  
Conventional Manual Call Points.

#### **1.1 - DMOCLIE<sub>x</sub> - Conventional**

DMOCLIE <sub>x</sub>	Board with simple switch.
Type	Type A (simple action) by displacing the frangible element
Protection Index	IP 33 Indoor.
Working Temperature	-20°C to 55°C
Frangible Element	Resettable.
Power Supply	20 VDC (13 to 28 VDC)
Ex Marking	IIC ia T6 Ga II 1 G

#### **1.2 - DMCL05 - Conventional**

DMCL05	Board with simple switch.
Type	Type A (simple action) by displacing the frangible element
Protection Index	IP 33 Indoor.
Working Temperature	-10°C to 60°C
Frangible Element	Resettable.
Power Supply	20 VDC (13 to 30 VDC)

### **2. DOCUMENTS AND DRAWINGS:**

#### **DEF/DETECTOMAT:**

- DMCL05FEX: BOM No. NOM124 Rev. B, dated Jun 5, 2012.
- Drawings No. FA750E Ind. B, dated Jun 21, 2012.
- DMOCLIE<sub>x</sub>: Technical Booklet - Installation and Wiring No. DMC\_NTP\_482 Rev. B, dated Jun 11, 2019.
- DMCL05 - Technical Booklet No. DMCNTP\_125 Rev. B, dated Jun 07, 2019.

### **3. TEST REPORTS:**

#### **CNPP:**

- DMCL05FEX: Test Reports according to EN 54-11 No. DI 12 00 16, dated Sep 28, 2012
- DMCL05FEX: Fire Security System Attestation No. DC 12 00 03, dated Oct 2, 2012

#### **LNE:**

- Test Reports according to IACS UR E10 No. P131074 DE/6, dated Aug 8, 2014

#### **LCIE:**

- Ex Certification No. LCIE 12 ATEX 3028 X, dated May 30, 2012.

#### **FARE:**

- Declaration of performance No. 0333-CPR-075182 for DMCL05 , dated Mar 28, 2019.

**4. APPLICATION / LIMITATION:**

- 4.1 - As per Requirements of Regulations stated on the front page of this certificate.
- 4.2 - The equipment fulfils the EMC requirements for installation on the Bridge and Deck Zone.
- 4.3 - Prior to fit on board, assessment of compatibility or connectability with fire alarm unit is to be performed.
- 4.4 - Hardware successfully tested in compliance with the regulations as referred to in page one, according to the declaration of the manufacturer are covered by this certificate.
- 4.5 - For Conventional Manual Call Points DMOCLIEx :
- In case of installation in Hazardous Area, a type approved I.S barrier, is to be fitted in safe Area, to limit the electrical power on the detection line.
  - The detection line must be equipped with fire detectors and/or manual call points with an ATEX certification.
  - All intrinsically safe wiring shall be kept separate from non-intrinsically safe wiring.
- 4.6 - The following component(s) shall comply with the requirements of MED2014/90/EU, as amended, and be wheelmarked:
- DMOCLIEx and DMCL05.

**5. PRODUCTION SURVEY REQUIREMENTS:**

- 5.1 - This certificate does not allow the applicant to issue the Declaration of Conformity and to affix the mark of conformity (wheelmark) to the products corresponding to this type. To this end, the production-control phase module D "Production Quality Assurance" or E "Product Quality Assurance" or F "Product Verification" of Annex B of the Directive is to be complied with and controlled by a written inspection agreement with a Notified Body.
- 5.2 - For information concerning the production phase modules, **DETECTOMAT SYSTEM** has declared the following manufacturing places :

**FARE**  
**ZA de la Guinette**  
**Route Duhamel du Monceau**  
**45300 Dadonville**  
**FRANCE**

**6. MARKING OF PRODUCT:**

- 6.1 - Maker's name or trade mark,
- Serial number of the units,
  - Equipment type number or model identification under which it was type-tested.
  - Type designation
  - Standard N°
  - Specification of terminals
  - Software version N°
- 6.2 - Reference is made to MED 2014/90/EU chapter 2.

In particular Article 10.3 specifies that the wheelmark shall be followed by the identification number of the Notified Body involved in the production control phase (module D, E or F) and by the year in which the mark is affixed (4 digits or last 2 digits).

**7. OTHERS:**

- 7.1 - It is **DETECTOMAT SYSTEM**'s responsibility to inform shipbuilders or their sub-contractors of the proper methods of fitting, use and general maintenance of the approved equipment and the conditions of this approval.
- 7.2 - This certificate supersedes the EC Type Examination Certificate No.44225/A1 MED issued on 25 Sep 2019 by the Society.

\*\*\* END OF CERTIFICATE \*\*\*