



Marine & Offshore

Certificate number: 43994/B0 MED

File number: AP 4685

Item number: MED/3.51d

This certificate is not valid when presented without the full attached schedule composed of 7 sections
www.veristar.com

Notified Body 2690 - MARINE EQUIPMENT DIRECTIVE 2014/90/EU

EC TYPE EXAMINATION CERTIFICATE

as per Module B of Directive 2014/90/EU of the European Parliament and of the Council of 23 July 2014 as transposed in the French Regulations and Commission Implementing Regulation (EU) 2021/1158 of 22 June 2021

This certificate is issued to:

DETECTOMAT SYSTEM

AHRENSBURG - GERMANY

for the type of product

FIXED FIRE DETECTION AND FIRE ALARM SYSTEMS COMPONENTS [...] - SMOKE DETECTORS: POINT DETECTORS USING SCATTERED LIGHT, TRANSMITTED LIGHT OR IONIZATION

OC-OIEx and OC05

Requirements:

IMO Res. MSC.36(63) -(1994 HSC Code)- as amended, 7

IMO Res. MSC.97(73) -(2000 HSC Code)- as amended, 7

IMO Res. MSC.98(73) -(FSS Code)- as amended, 9

IMO Res. MSC.391(95) -(FSS Code)- as amended, 9

IMO MSC.1/Circ.1242 -(IGF Code)- as amended, 11

EN 54-7:2018

As applic., electrical and electronic installation in ships:

IEC 60092-504 :2016

IEC 60533:2015


This certificate is issued on behalf of the French Maritime Authorities to attest that Bureau Veritas Marine & Offshore did undertake the relevant type-examination procedures for the product identified above which was found to comply with the relevant requirements of the Directive 2014/90/EU of the European Parliament and of the Council of 23 July 2014 as transposed in the French Regulations.

This certificate will expire on: 11 Oct 2026**For Bureau Veritas Marine & Offshore Notified Body 2690,**

At BV SAINT-NAZAIRE, on 11 Oct 2021,

Francois LOPINOT



This certificate does not allow to issue the Declaration of Conformity and to affix the mark of conformity (wheelmark ) to the products corresponding to this type. To this end, the production-control phase module (D, E or F) of Annex II of the Directive is to be complied with and controlled by a written inspection agreement with a notified body.

This certificate remains valid until the date stated above, unless cancelled or revoked, provided the conditions indicated in the subsequent page(s) are complied with and the product remains satisfactory in service. This certificate will not be valid if the applicant makes any changes or modifications to the approved product, which have not been notified to, and agreed in writing with Bureau Veritas Marine & Offshore. Should the specified regulations or standards be amended during the validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on board vessels to which the amended regulations or standards apply. Bureau Veritas Marine & Offshore is designated by the French Maritime Authority as a "notified body" under the terms of the French Regulations Division 140 Chapter 140-2. This certificate is issued within the scope of the General Conditions of Bureau Veritas Marine & Offshore available on the internet site www.veristar.com. Any Person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas Marine & Offshore for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by personnel of the Society or of its Agents in establishment or issuance of this document, and in connection with any activities for which it may provide.

THE SCHEDULE OF APPROVAL

1. PRODUCT DESCRIPTION:

- Product model or type designation :
OC-OIEx and OC05
- Product description:
Conventional Smoke Detector.

1.1 - Main Characteristics of OC-OIEx Detector:

OC-OIEx	Conventional Detector.
Principle	Point Detector using a scattered light
Protection Index	IP 32 Indoor
Working Temperature	-20°C to +55°C
Power Supply	20 VDC (10 to 28 VDC)
Software Version	2.0.x
Ex Marking	Ex ia IIC T6 Ga, II 1 G

1.2 - Main Characteristics of OC05 Detector:

OC05	Conventional Detector
Principle	Point Detector using a scattered light
Response Threshold Value	Not Adjustable
Protection Index	IP 32 Indoor
Working Temperature	-10°C to 60°C
Power Supply	20 VDC (10 to 27 VDC)
Software Version	1.1x
Bases	S05, S12

2. DOCUMENTS AND DRAWINGS:

DEF/DETECTOMAT:

	OC05	OC-OIEx
Electrical Scheme	FA424E rev.B dated 07/09/2026	FB314E rev.C dated 13/09/2016
BOM	NOM085 rev.C dated 07/07/2016	NOM216 Rev. B dated 04/02/2015
Software revision	FIL_ORION(-S)_C dated 02/06/2010	FIL_OC05FEX dated 03/06/2014
Technical Booket installation and wiring	OC05M_NTP_083 rev. C dated 08/02/2019	DPC_NTP_480 rev. B dated 08/06/2019

3. TEST REPORTS:

CNPP:

- OC-OIEx: Test Reports according to EN 54-7 No. DE 13 00 14, dated June 14, 2013 + DE 15 00 28, dated Sept 17, 2015
- OC 05: Test Report according to EN 54-7 No. DE 04 00 03A dated Dec 7, 2016.
- OC05FEX: Test Reports according to EN 54-7 No. DE 12 00 26 Rev A, dated Sep 17, 2015.
- OC05FEX: EMC Test Report No. LM 15 00 58, dated Aug 6, 2015

LNE:

- Test Reports according to IACS UR E10 No. P131074 DE/2, dated Oct 9, 2014
- Test Report No. P190832_DEC/1, dated Apr 03, 2019.

LCIE:

- Ex Certification No. LCIE 15 ATEX 3022 X Issue 0, dated Sep 10, 2015.

AFNOR Certification:

- Certificate of Conformity No. 0333-CPR-075013, dated Feb 07, 2018.
- Certificate of Conformity No. 0333-CPR-075449, dated Feb 07, 2018.

4. APPLICATION / LIMITATION:

- 4.1 - As per Requirements of Regulations stated on the front page of this certificate.
- 4.2 - The equipment fulfils the EMC requirements for installation on the Bridge and Deck Zone.
- 4.3 - The equipment is not be fitted in refrigerated chambers.
- 4.4 - Prior to fit on board, assessment of compatibility or connectability with fire alarm unit is to be performed.
- 4.5 - Only Hardware and Software successfully tested together in compliance with the regulations as referred to in page one, according to the declaration of the manufacturer are covered by this certificate.
- 4.6 - In case of installation in Hazardous Area, a type approved I.S barrier, is to be fitted in safe Area, to limit the electrical power on the detection line.
- 4.8 - All intrinsically safe wiring shall be kept separate from non-intrinsically safe wiring.
- 4.9 - The following component(s) shall comply with the requirements of MED2014/90/EU, as amended, and be wheelmarked:
 - OC-OIEx and OC05.

5. PRODUCTION SURVEY REQUIREMENTS:

- 5.1 - This certificate does not allow the applicant to issue the Declaration of Conformity and to affix the mark of conformity (wheelmark) to the products corresponding to this type. To this end, the production-control phase module D "Production Quality Assurance" or E "Product Quality Assurance" or F "Product Verification" of Annex B of the Directive is to be complied with and controlled by a written inspection agreement with a Notified Body.
- 5.2 - For information concerning the production phase modules, **DETECTOMAT SYSTEM** has declared the following manufacturing places :

**FARE
ZA de la Guinette
Route Duhamel du Monceau
45300 Dadonville
FRANCE**

6. MARKING OF PRODUCT:

- 6.1 - Maker's name or trademark,
 - Serial number of the units,
 - Equipment type number or model identification under which it was type-tested.
 - Class of detector
 - Standard N°
 - Wiring terminal designation
 - Software version N°

- 6.2 - Reference is made to MED 2014/90/EU chapter 2.

In particular Article 10.3 specifies that the wheelmark shall be followed by the identification number of the Notified Body involved in the production control phase (module D, E or F) and by the year in which the mark is affixed (4 digits or last 2 digits).

7. OTHERS:

- 7.1 - It is **DETECTOMAT SYSTEM**'s responsibility to inform shipbuilders or their sub-contractors of the proper methods of fitting, use and general maintenance of the approved equipment and the conditions of this approval.
- 7.2 - This certificate supersedes the EC Type Examination Certificate No. 43994/A1 MED issued on 25 Sep 2019 by the Society.

*** END OF CERTIFICATE ***