

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

**0905-CPR-00269**

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

**Product(s):** SmartCell range of wireless fire alarm devices, Dual Input & output device (FIRE)  
(refer to attached appendix for details and conditions)

**Placed on the market  
under the name or trade mark of:** EMS Security Group Limited  
Technology House, Sea Street  
Herne Bay, Kent, CT6 8JZ  
United Kingdom

**and produced in the  
manufacturing plant(s):** Carrier Manufacturing Poland Sp. Zo.o. (SG- 24159)  
ul Kolejowa 24  
39-100 Ropczyce  
Poland

**Intended use:** Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

**EN 54-25:2008+AC:2012**  
**EN 54-18:2005+AC:2007**

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00269** on **2019-08-16** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

## Notified Body 0905

**Certification Manager:** Dipl.-Ing. Bernhard Miedtank

**Date Issue:** 2023-09-27

**Issue:** 2

**Signature:**

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

**0905-CPR-00269**

## APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00269

The details and conditions of use for the SmartCell range of wireless fire alarm devices, Dual Input & output device (FIRE) , placed on the market under the name or trade mark of:

### EMS Security Group Limited

Technology House, Sea Street, Herne Bay, Kent, CT6 8JZ, United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

**Products compliant with EN 54-25:2008+AC:2012, EN 54-18:2005+AC:2007**

| Model           | Manufacturing Location | Description  |
|-----------------|------------------------|--|
| SC-41-0200-0000 | SG-24159               | SmartCell range of wireless fire alarm devices, Dual Input and Output device |

### Batteries:

The following batteries are approved for use with the product(s) listed:

| Manufacturer             | Model type |
|--------------------------|------------|
| EVE (ENERGY VERY ENDURE) | ER14505M   |
| FANSO                    | ER14505M   |
| HCB                      | ER14505M   |

### Packing variants:

Additional packing code information following the model number:

XX-YY-ZZZZ-BBBB-CC

Product Family: X

Product Line: X

Group: Y

Type: Y

Power: Z

Colour: Z

Indication: Z

Variant: Z

Branding B

Branding B

Branding B

Branding B

Country Code C

Country Code C

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

**Intertek Deutschland GmbH, Stangenstraße 1, 70771 Leinfelden-Echterdingen**  
Tel.: +49 711 27311-0 E-Mail: [nb0905@intertek.com](mailto:nb0905@intertek.com) Web: [www.intertek.de](http://www.intertek.de)

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

**0905-CPR-00269**

## APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00269

The 4-digit branding code relates to packing codes for branded variants. Details are maintained in controlled document - EMS Document BRAND-0001 EMS SmartCell Product Range - Customer Branding Specification.

The 2-digit Country Code relates to packing codes for specific country variants.

### Conditions of use:

Suitable for indoor applications only.

### General Notes:

1. Evaluated under Intertek project number 101317801, G104828711.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.