

# CERTIFICATE

## 0960-CPR-SKG.1388.3643.04.ENG

Issued: 27-11-2018  
Valid until: 27-11-2023

Replaces: 0960-CPR-SKG.1388.3643.03.EN  
Issued: 30-07-2015



### Certificate holder

Sense-WARE Fire and Gas Detection BV  
Storkstraat 7  
3905 KX Veenendaal  
T: +31 (0)88 736 7300  
E: eu@sense-ware.com  
I: www.sense-ware.com

## Certificate of constancy of performance

### Declaration of SKG-IKOB (Notified Body 0960)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### FLAME DETECTORS

as specified in the attached appendix placed on the market under the name or trade mark of the holder of this certificate and produced by the holder of this certificate or for the holder of this certificate in the manufacturing plant(s) if mentioned above.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

### EN 54-10:2002

and

### EN 54-10:2002/A1:2005

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued on 07-12-2012 and will remain valid until the date as mentioned at this certificate as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

For SKG-IKOB

A handwritten signature in blue ink, appearing to be 'ir. H.A.J. van Dartel', written over a horizontal line.

ir. H.A.J. van Dartel  
Certification manager

The users of this certificate are advised to verify at [www.skgikob.nl](http://www.skgikob.nl) if this certificate is still valid and actual.  
This certificate consists of 2 pages.



SKG-IKOB Certificatie  
Poppenbouwing 56  
4191 NZ Geldermalsen

Postbus 202  
4190 CE Geldermalsen

T 088-2440100  
info@skgikob.nl  
www.skgikob.nl

CERTIFICATE

# CERTIFICATE

Sense-WARE Fire and Gas Detection BV  
Number: 0960-CPR-SKG.1388.3643.04.ENG

Page 2 of 2

## Appendix 1 CERTIFICATE OF CONSTANCY OF PERFORMANCE

Article	Specification	Classification according to EN 54-10	SKG-IKOB - ITT (report nr.)
IR3-109/1 (C/CZ)	Infrared Flame Detector	Class 1	15.00633

Article	Specification	Classification according to EN 54-10	SKG-IKOB - ITT (report nr.)
UV-185/5 (C/CZ)	Ultraviolet Flame Detector	Class 2	11-407 13.00220

Article	Specification	Classification according to EN 54-10	SKG-IKOB - ITT (report nr.)
UV/IR-210/1 (C/CZ)	Ultraviolet / Infrared Flame Detector	Class 2	11-407