



CERTIFICATE OF CONSTANCY OF PERFORMANCE

0051 – CPR – 0267

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation, or CPR), this Certificate applies to the construction product

POWER SUPPLY EQUIPMENT FOR FIRE DETECTION AND FIRE ALARM SYSTEMS

Trademark: **VENITEM**
Model: **TUL375 EN**

Other information: **see ANNEX**

Produced by:
VENITEM S.r.l
Via del Lavoro 10 – 30030 Salzano (VE), Italy

In the manufacturing plant(s):
PI.H000EK

This Certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-4:1997 + A1:2002 + A2:2006

under system **1** are applied and that **the product fulfills all the prescribed requirements set out above.**

This certificate cancels and replaces the certificate having the same number and issued on 2016-07-28 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.


ING. V. BAGGIO
CPR TECHNICAL DIRECTOR

DocuSign

Milan, 2020-01-27

This Certificate was issued by IMQ S.p.A., a Notified Body according to Regulation (EU) No. 305/2011.
IMQ S.p.A. Identification Number is: 0051.

ANNEX

0051–CPR–0267

Configuration

It is contained in a metallic enclosure with grade IP30. Internally it is fitted with the following main parts:

- No. 1 Power supply board type AL1/EN Rev. 0;
- No. 1 LED board type TCA/4;
- No. 1 Mains transformer trademark TECTOR type 3250-04/28;
- No. 2 allocable batteries 12 V – 17 Ah.

Output power supply distribution:

- 3 A current for external devices;
- 2 A current for battery recharge.



DECLARATION OF PERFORMANCE

02/08/16
DP-AL-T375-01-01
Rev.01
Page 1 of 2

According to Construction Products Regulation EU N° 305/2011

DoP N° 0051 – CPR - 0267

1. Unique identification code of the product-type:
TUL375EN – POWER SUPPLY EQUIPMENT
2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):
TUL375EN
3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:
FIRE DETECTION AND FIRE ALARM SYSTEMS INSTALLED IN BUILDINGS
4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):
VENITEM srl via Del lavoro, 10 – 30030 Salzano (VE)
5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):
Not Applicable
6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:
System 1
7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:
IMQ S.p.a. 0051
performed type testing, and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance, assessment and approval of the factory production control under System 1 and issued the EC certificates of conformity
0051-CPR-0267
8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:
Not Applicable, see item 7
9. Declared performance
All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in point 3 above have been determined as described in the EN54-4 mentioned in the table below.



DECLARATION OF PERFORMANCE

02/08/16

DP-AL-T375-01-01

Rev.01

Page 2 of 2

Essential characteristics	Performance	Harmonised technical specification
Performance of power supply	Pass	EN54-4:1997 + A1:2002 + A2:2006 Art.: 4, 5, 6
Operational reliability	Pass	EN54-4:1997 + A1:2002 + A2:2006 Art.: 4, 5, 6, 7, 8
Durability of operational reliability and response delay, temperature resistance	Pass	EN54-4:1997 + A1:2002 + A2:2006 Art.: 9.5
Durability of operational reliability, vibration resistance	Pass	EN54-4:1997 + A1:2002 + A2:2006 Art.: 9.7, 9.8, 9.15
Durability of operational reliability, electrical stability	Pass	EN54-4:1997 + A1:2002 + A2:2006 Art.: da 9.9 a 9.13
Durability of operational reliability, humidity resistance	Pass	EN54-4:1997 + A1:2002 + A2:2006 Art.: 9.6, 9.14

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by

Manente Marcello; R & D Director

Signature

Salzano, 2nd August 2016

Venitem Srl

Sede legale e operativa:
Via del Lavoro, 10
30030 Salzano (Venezia)
ITALY

Tel. +39.041.5740374
Fax +39.041.5740388
info@venitem.com
www@venitem.com

AZIENDA CERTIFICATA



Aderente a:
CONFINDUSTRIA
VENEZIA

DESIGN E
PRODUZIONE
IN ITALIA
ITALIAN DESIGN AND PRODUCTION