



Constancy of Performance Certificate

LGA Technological Center S.A. (APPLUS), Notified Body No. 0370, issues this certificate to:

APPLICANT

Placed on the market under the name of

Easy Detect, S.L.

Paseo Ferrocarriles Catalanes, 143
08940 Cornellà De Llobregat (Barcelona) Spain

Manufactured in production plant

Paseo Ferrocarriles Catalanes, 143
08940 Cornellà De Llobregat (Barcelona) Spain

PRODUCT

Fire detection and fire alarm systems

- Smoke detectors: point detectors using scattered light, transmitted light or ionization
- Short-circuit isolators

Models: DOE-120-AI / DOE-120-AIB **Brand:** Easydetect

APPLICABLE REGULATION

Construction Product Regulation (CPR)

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9 March 2011

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards:

EN 54-7:2018; EN 54-17:2005, EN 54-17:2005/AC:2007

Under **system 1** for the performance set out in this certificate are applied and the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

No. 0370-CPR-7197

Date issued: 20/06/2025

First issue date: 02/08/2024

Follow-up date: before 31/07/2026

The validity of this certificate remains valid as long as the harmonised standard, the construction product, the EVCP methods and the manufacturing conditions at the plant are not significantly modified, unless suspended or withdrawn by the notified product certification body.

This document is not valid without its technical annex; whose number coincides with that of the certificate.

Xavier Ruiz Peña
Managing Director
Conformity Assessment



LGA Technological Center S.A. (APPLUS)
Notified Body No. 0370
Campus UAB. Ronda de la Font del Carme s/n
08193 Bellaterra, Barcelona (Spain)



Check the status
of this certificate

Certificate

Technical Annex

Annex according to EN 54-7:2018

Fire detection and fire alarm systems. Part 7: smoke detectors: point detectors using scattered light, transmitted light or ionization

Essential characteristics	Clauses in this European standard	Mandated level(s) or class(es)
Individual alarm indication	4.2.1.	Pass
Connection of ancillary devices	4.2.2.	NA
Monitoring of detachable detectors	4.2.3.	Pass
Manufacturer's adjustments	4.2.4.	Pass
On-site adjustment of response behaviour	4.2.5.	Pass
Protection against the ingress of foreign bodies	4.2.6.	Pass
Response to slowly developing fires	4.2.7.	Pass
Software controlled detector	4.2.8.	Pass
Repeatability	4.3.1.	Pass
Directional dependence	4.3.2.	Pass
Reproducibility	4.3.3.	Pass
Air movement	4.4.1.	Pass
Dazzling	4.4.2.	Pass
Variation in supply parameters	4.5.	Pass
Fire sensitivity	4.6.	Pass
Cold (operational)	4.7.1.1.	Pass
Dry heat (operational)	4.7.1.2.	Pass
Damp heat, steady state (operational)	4.7.2.1.	Pass
Damp heat, steady state (endurance)	4.7.2.2.	Pass
Sulfur dioxide (SO ₂) corrosion (endurance)	4.7.3.	Pass
Shock (operational)	4.7.4.1.	Pass
Impact (operational)	4.7.4.2.	Pass
Vibration, sinusoidal (operational)	4.7.4.3.	Pass
Vibration, sinusoidal (endurance)	4.7.4.4.	Pass
Electromagnetic compatibility (EMC), immunity tests (operational)	4.7.5.	Pass

PASS; NPD = No Performance Determined, NA = Not Apply

Annex according to EN 54-17:2005, EN 54-17:2005/AC:2007

Fire detection and fire alarm system. Part 17: short-circuit isolators

Essential characteristics	Clauses in this European standard	Mandated level(s) or class(es)
Compliance	4.1	Pass
Integral status indication	4.2	NA
Connection of ancillary devices	4.3	NA
Monitoring of detachable short-circuit isolators	4.4	Pass
Manufacturer's adjustments	4.5	NA
On-site adjustments	4.6	NA
Marking	4.7	Pass
Data	4.8	Pass
Additional requirements for software controlled short-circuit isolators	4.9	Pass
Reproducibility	5.2	Pass
Variation in supply voltage	5.3	Pass
Dry heat (operational)	5.4	Pass
Cold (operational)	5.5	Pass
Damp heat, cyclic (operational)	5.6	Pass
Damp heat, steady state (endurance)	5.7	Pass
Sulphur dioxide (SO ₂) corrosion (endurance)	5.8	Pass
Shock (operational)	5.9	Pass
Impact (operational)	5.10	Pass
Vibration, sinusoidal (operational)	5.11	Pass
Vibration, sinusoidal (endurance))	5.12	Pass
Electromagnetic Compatibility (EMC), Immunity tests (operational)	5.13	Pass

PASS; NPD = No Performance Determined, NA = Not Apply

Accessories	
ZCE-100	Connection base
ZCE-100-B	Black connection base
ZCE-120	Connection base
ZCE-120-B	Black connection base