



Constancy of Performance Certificate

LGAI Technological Center S.A. (APPLUS), Notified Body No. 0370, issues this certificate to:

APPLICANT

Placed on the market under the name of

Easy Detect, S.L.

Paseo Ferrocarriles Catalanes, 143
08940 Cornellà De Llobregat (Barcelona) Spain

Manufactured in production plant

Paseo Ferrocarriles Catalanes, 143
08940 Cornellà De Llobregat (Barcelona) Spain

PRODUCT

Fire detection and fire alarm systems

□ Heat detectors. Point heat detectors

Models: DTE-115 / DTE-115-B **Brand:** Easydetect

APPLICABLE REGULATION

Construction Product Regulation (CPR)

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9 March 2011

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 54-5:2017+A1:2018

Under **system 1** for the performance set out in this certificate are applied and the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

No. 0370-CPR-7190

Date issued: 20/06/2025

First issue date: 02/08/2024

Follow-up date: before 31/07/2026

The validity of this certificate remains valid as long as the harmonised standard, the construction product, the EVCP methods and the manufacturing conditions at the plant are not significantly modified, unless suspended or withdrawn by the notified product certification body.

This document is not valid without its technical annex; whose number coincides with that of the certificate.

Xavier Ruiz Peña
Managing Director
Conformity Assessment



LGAI Technological Center S.A. (APPLUS)
Notified Body No. 0370
Campus UAB. Ronda de la Font del Carme s/n
08193 Bellaterra, Barcelona (Spain)



Check the status
of this certificate

Certificate

Technical Annex

Annex according to EN 54-5:2017+A1:2018

Fire detection and fire alarm systems. Part 5: heat detectors. Point heat detectors

Essential characteristics	Clauses in this European standard	Mandated level(s) or class(es)
Heat response categories	4.1.1.	Pass
Position of heat sensitive elements	4.2.1	Pass
Individual alarm indication	4.2.2.	Pass
Connection of ancillary devices	4.2.3.	NA
Monitoring of detachable detectors	4.2.4.	Pass
Manufacturer's adjustments	4.2.5.	Pass
On-site adjustment of response behaviour	4.2.6.	Pass
Software controlled detector (when provided)	4.2.7.	Pass
Directional dependence	4.3.1.	Pass
Static response temperature	4.3.2.	Pass
Response times from typical application temperature	4.3.3.	Pass
Response times from 25 °C	4.3.4.	Pass
Response times from high ambient temperature	4.3.5.	Pass
Reproducibility	4.3.6.	Pass
Additional tests for suffix S detectors	4.4.1.	NA
Additional tests for suffix R detectors	4.4.2.	NA
Variation in supply parameters	4.5.1.	Pass
Cold (operational)	4.6.1.1.	Pass
Dry heat (endurance)	4.6.1.2.	Pass
Damp heat, cyclic (operational)	4.6.2.1.	Pass
Damp heat, steady state (endurance)	4.6.2.2.	Pass
Sulphur dioxide (SO ₂) corrosion (endurance)	4.6.3.	Pass
Shock (operational)	4.6.4.1.	Pass
Impact (operational)	4.6.4.2.	Pass
Vibration, sinusoidal (operational)	4.6.4.3.	Pass
Vibration, sinusoidal (endurance)	4.6.4.4.	Pass
Electromagnetic compatibility (EMC), immunity tests (operational)	4.6.5.	Pass

PASS; NPD = No Performance Determined, NA = Not Apply

Accessories	
ZCE-100	Connection base
ZCE-100-B	Black connection base
ZCE-120	Connection base
ZCE-120-B	Black connection base